

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. TL/21/2025

Dated: 27/6/2025

It is certified that an inspection team headed by Mukesh B. Ruvut (Lab Analyst)

(Name of Officers with designation) from GWSSB Limkheda PHED

inspected the EMR School, Lakhadiga (Taluka: Dharmpur)

(Name & Address of the school) on 27/06/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 150/2025-26 dated 27/06/2025

of GWSSB Limkheda (PHED Lab) certified that the

EMR School, Lakhadiga (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Six Months from Report

Signature with Seal: Deputy
Name: Deputy Executive Engineer
Designation: Public Health Sanitary Sub Division
Name & Address of the Office / Department: Limkheda

To EMR School, Lakhadiga
AT: Lakhadiga, Post: Dharmpur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Taluka Laboratory,
Limkheda,
Gujarat Water Supply &
Sewerage Board
Front of New Court, Zulelal
Ganaral 1st Floor, Godhara
Road Limkheda, 389140 Ph -
02677-229782



E mail :
limkhedalab123@gmail.com

તાલુકા પ્રયોગશાળા, લીમખેડા,
ગુ.પા.પુ.અને ગ.વ્ય.બોર્ડ, નવી કોર્ટ સામે,
ગુલેલાલ જનરલ સ્ટોર, પહેલો માળ,
ગોધરા રોડ લીમખેડા-૩૮૯૧૪૦, કોન-
૦૨૬૭૭-૨૨૯૭૮૨

TL/7.8/F-01

NABL Recognized
Laboratory
Certificate No. NABL-DWT-
01064
Valid Up To: 17-03-2028

Name & Address of Customer:-

Principal
EMRS Lakhadiya Ta, Dhanpur
Dist-Dahod

Test Report

Customer Reference No. : EMRS/LUK/2025-26/OP-54

Sample Submitted by : Customer

Date of Sample Receipt : 25-06-25

Analysis Starting Date : 26-06-25

Analysis completion Date : 26-06-25

ULR No : ---

Discipline : Chemical Testing, Group: Water

Date of Issue : 27-06-25

Mode of Sample : Satisfactory

Source : Tube Well

Habitation : School Falia

District : Dahod

Longitude : ---

Latitude : ---

Sample Type : Drinking Water

Test Report No:	150/2025-26
Sample ID :	LCW-150/06-25
Main Source :	Ground Water
Location :	In EMRS Compaund
Village :	Lukhadiya
Taluka :	Dhanpur
Latitude :	---

Kindly find herewith the Analytical Results.

Sr. No.	Parameter	Unit	IS-10500:2012 (2nd Revision)		Reference Method :	Analytical Value
			Requirement (Acceptable Limit) Max.	Permissible Limit in the Absence of Alternate Source Max.		
1	Colour	Hazen	5	15	APHA (23 rd Ed.2017), Method: 2120 B	<5
2	Odour	-	Agreeable	Agreeable	IS 3025 (Part 5) - 2018 (Second Revision)	Agreeable
3	Taste	-	Agreeable	Agreeable	IS 3025 (Part 8) -1984 (Reaffirmed 2017)	Agreeable
4	Turbidity	NTU	1	5	APHA (23 rd Ed.2017), Method: 2130 B	1.02
5	pH at 25°C	-	6.5 to 8.5	No relaxation	APHA (23 rd Ed.2017) Method: 4500 H ⁺ B	7.35
6	Total Dissolved Solids	mg/l	500	2000	APHA (23 rd Ed.2017) Method: 2540 C	354
7	Total Hardness(as CaCO ₃)	mg/l	200	600	APHA (23 rd Ed.2017) Method: 2340 C	212
8	Calcium (as Ca ⁺²)	mg/l	75	200	APHA (23 rd Ed.2017) Method: 3500 Ca ⁺² B	49
9	Magnesium (as Mg ⁺²)	mg/l	30	100	APHA (23 rd Ed.2017) Method: 3500-Mg ⁺² B	21
10	Chloride (as Cl ⁻)	mg/l	250	1000	APHA (23 rd Ed.2017) Method: 4500-Cl ⁻ B	40
11	Sulphate (as SO ₄ ⁻²)	mg/l	200	400	APHA (23 rd Ed.2017) Method: 4500-SO ₄ ⁻² E	16
12	Nitrate (as NO ₃ ⁻)	mg/l	45	No relaxation	APHA (23 rd Ed.2017) Method: 4500-NO ₃ ⁻ B	27.36
13	Fluoride (as F ⁻)	mg/l	1.00	1.50	APHA (23 rd Ed.2017) Method: 4500-F ⁻ C	0.86
14	Total Alkalinity (as CaCO ₃)	mg/l	200	600	APHA (23 rd Ed.2017) Method: 2320 B	220

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500 2012 (2nd Revision) Limits.

Issued By:

Ravat Mukeshbhai B. Lab Analyst

Name & Designation of

Authorized Signatory

O.W.No. TL/ 21 /of 2025, Dt. 27/06 / 2025.

End of the Test Report